

Murray City Fire Department Inspection Checklist

1. EXITS:

- Not opening in the proper direction
- Door(s) locked or blocked
- Door(s) in need of repair
- Sign(s) not illuminated
- Directional signs needed
- Emergency lighting needed for corridors and stairways

2. FIRE PROTECTION INSTALLATION:

- Maintain access to standpipes, hose racks, FDC, and fire sprinkler controls/valves
- Spare sprinkler heads and wrench not provided
- Inspect/service hood, ducts, and ANSUL system
- Identify and secure sprinkler valves
- Annual/5-year inspection past due
- FDC caps are missing or damaged
- Incomplete system/unprotected areas
- Riser room signage required
- Annual fire alarm inspection past due
- Proof of fire sprinkler supervision required

3. FIRE EXTINGUISHERS:

- Insufficient number/type (2A:100B:C)
- Shall be mounted every 75 feet
- Obstructed
- Sign(s) indicating location needed
- Annual inspection past due

4. ELECTRICAL:

- Improper use of extension cords
- Protective cover(s) missing
- Blank covers missing in breaker panel
- Breakers taped open
- Breaker not labeled
- Defective or exposed wiring
- Improper use of multi-plug adapters

5. FLAMMABLE LIQUIDS:

- Improper use
- Improper storage
- Improper dispensing
- Improper storage container

6. STORAGE:

- Storage too close to ceiling or sprinkler heads (18-24" clearance)
- Too close to furnace or hot water heater (30" min)
- Blocking electrical panel (30" clearance)
- Boiler, mechanical, and electrical rooms shall remain clear
- Remove storage beneath unprotected stairways
- Blocking aisleways or exits
- Disorderly or excessive storage of combustibles
- Rubbish, waste, and oily rags shall be stored in proper containers

7. MISCELLANEOUS:

- Remove waste and trash from around the exterior of the building
- "No Smoking" signs shall be posted
- Address shall be posted on building and visible from street
- High-pressure cylinders shall be secured
- Protective post required
- Occupant load shall be posted
- Fire-rated doors wedged open
- Penetrations in fire-rated construction
- Fire lane/fire hydrant obstructed
- MSDS sheets not available on site
- Knox Box (Model 3200) mounted at 5' & unobstructed