



TANK INSTALL/REMOVAL

In order to obtain an application for flammable liquid storage tanks please submit request to firemarshal@Murray.utah.gov to setup a date and time to have the tank installed or pulled.

A plan or drawing is required in order for an approval stamp and permit to be applied

- Tanks are clearly marked with "Flammable" and either "LP-gas" or "Propane".
- Portable containers for temporary stationary use are placed on concrete pads, paved surfaces or firm earth.
- Approved vehicle protection shall be provided when containers are exposed to probable damage due to proximity to alleys, driveways or parking areas.
- Clearance from combustibles shall be kept not less than 10 feet from tanks or containers.
- Containers used in buildings under construction or undergoing major renovation follow appropriate codes and standards.
- Clearance from heat-producing appliances and combustibles shall be maintained as set forth by the appliance listing and as approved.
- Fire extinguishers of an approved rating are provided, visible, and accessible throughout the structure where there are combustibles and open flame devices used.
- Storage areas shall be kept free from weeds and extraneous combustible material. Open flames and smoking prohibited in storage area.
- Tanks and containers shall be conspicuously marked with name of product and the words "Flammable-Keep Fire and Flame Away" and "Keep 50 Feet from Building".
- Outdoor storage areas shall be provided with drainage control or diking as set forth in IFC

The permit is not transferable and is good only for the location specified, it must be available for inspection at any time by authorized persons and may be revoked for cause as provided by city ordinance or by violation of safety regulations, as set by the Murray City Fire Marshal, provided no changes or modifications or additions are made. ****This for does not duplicate Utah State Marshal rule R710-6* Liquefied Petroleum Gas Rules. * it is intended for site plan review only.