



EV CHARGING STATIONS SUBMITTAL

All new commercial EV charging station installations and existing system additions or modifications require a plan submittal and permit from Murray City Fire Marshals Office.

Third Party Review is NOT required for EV charging station installations and existing system additions or modifications.

Plans must show designer certification number with signature or Engineer Stamp with signature.

Murray City Fire Department requires the installation of a KNOXBOX remote power box to remotely operate a shunt trip breaker to disconnect power.

Design and installation shall be via the most recent version of NFPA 70 (Article 625) adopted by the State of Utah.

Working plans shall be drawn to an indicated scale, on sheets of uniform size.

*Manufacturer cut sheets shall be provided.

*Horn/strobe, exits, pull stations, and sprinkler locations shall be indicated on the plans (if applicable).

Email plans to firemarshal@murray.utah.gov